



SECTION A-A

TIER 22 RATED:
 VERTICAL DESIGN LOAD 22,500 LBS
 VERTICAL TEST LOAD 33,750 LBS

DRAWN BY: JESSE GUTTING	
CREATED DATE: 12/8/2022	REVISION LEVEL: 0
SAVED DATE: 12/8/2022	SAVED BY: jgutting
WEIGHT: 168 LBS.	MATERIAL: NOTED



CONCAST
 1010 NORTH STAR DRIVE
 P.O. BOX 69
 ZUMBROTA, MN 55992-0069

DESCRIPTION: POLYMER CONCRETE HAND HOLE		SHEET 1 OF 1
DIMENSIONS ARE IN INCHES TOLERANCES: FRACTIONAL: $\pm 1/8\text{'}$ ANGULAR: $\pm 2^\circ$	CONTACT INFORMATION: EMAIL: INFO@CONCASTINC.COM PHONE: (507) 732-4095 FAX: (507) 732-4094	
PART NUMBER: PH22-17-30-18		